

**KINDER MORGAN ENERGY PARTNERS, L.P.  
SUPPLIER QUALITY CERTIFICATION  
TURBINE FUEL**

**SUPPLIER:** \_\_\_\_\_ **SOURCED THROUGH:** \_\_\_\_\_

**TENDER NO:** \_\_\_\_\_ **DATE:** \_\_\_\_\_

			KMEP Use Only	
Flash Point, °F	D-56	_____	105 °F	_____
Gravity, API	D-1298, D-4052	_____	37.0-51.0	_____
<b>One</b> of the following distillation methods:				
Physical Distillation	D-86			
10% recovered, °F		_____	401 °F max	_____
Final Boiling Point, °F		_____	572 °F max	_____
<b>-- OR --</b>				
Simulated Distillation	D-2887			
10% recovered, °F		_____	365 °F max	_____
Final Boiling Point, °F		_____	644 °F max	_____
Freeze point, °F	D-2386	_____	-40 °F max	_____
Copper strip, 2 h @ 212 °F	D-130	_____	No. 1	_____
Existent gum Mg/100mL	D-381	_____	7 max	_____
Micro Separometer	D-3948	_____	85 min	_____
Particulate Content	D-5452	_____	2.0 mg/L	_____

*(check one)*

This product contains no additives.

This product contains the following approved additives in the amounts specified :

\_\_\_\_\_

\_\_\_\_\_

This product meets requirements of ASTM D-1655

We certify the above to be true and correct

Authorized Signature \_\_\_\_\_ Date \_\_\_\_\_

Please provide **KMEP Pipeline Input Location** a copy of this completed report by fax at number indicated below for each batch tendered.

<u>Location</u>	<u>Fax Number</u>	<u>Phone Number</u>	<u>Location</u>	<u>Fax Number</u>	<u>Phone Number</u>
Concord	(925) 827-2971	(925) 682-6850	Richmond	(510) 232-1729	(510) 233-2027
Watson	(310) 763-1698	(323) 636-4447	El Paso	(915) 778-1111	(915) 772-7400